

Certificate of Assessment

Project No.: XC3283

Report No. EP153410

This is to certify that CSIRO Infrastructure Technologies have examined information submitted to us and appraised the suitability of the use of carpets in Class 1 to 10 buildings without further slip resistance testing in accordance with AS 4586 Appendix A on behalf of:

Carpet Institute of Australia Limited
Level 1, 493 St. Kilda Road
MELBOURNE, 3004 VICTORIA
AUSTRALIA

CSIRO Report EP153410 Revision D May 2020 describes the engineering assessment conducted to evaluate the compliance of the carpets with the NCC 2019 requirements. A statistical analysis was performed based on 102 test reports of tests carried out in accordance with AS 4586 Appendix A, tested without underlay from two test laboratories. A full description of the test specimens and the complete test results are detailed in the Report.

DESCRIPTION OF SAMPLE: Carpet of particular construction types as described in the CSIRO report. This report is valid for carpet manufactured by Beaulieu Australia, Brintons, Feltex Carpets, Cavalier Bremworth, Godfrey Hirst Carpets, Interface, Norman Ellison Carpets, Milliken-Ontera, Quest Carpets, Supertuft, Tuftmaster Carpets and Victoria Carpets. The assessment does not apply to:

- carpet of cut and loop combination pile
- loop pile carpets with pile fibre of other than wool or nylon (i.e. polypropylene, polyester and triexta)
- carpets from manufacturers not listed above


CONCLUSION: There is sufficient evidence that the Slip Resistance Classification (SRC) of carpets will satisfy Performance Requirements DP2 of the BCA Vol 1 and Performance Requirements P2.5.1 of the BCA Vol 2 without further testing. With 99.9% confidence, samples of various types of carpets can be expected to have an SRC assessed as not less than P3 as required by the NCC for dry stairs, landings and ramps if tested under AS 4586 Appendix A. This depends on the fibre type, fibre style and the Pile Thickness (PT). The conclusion is limited to the values achieved by construction types assessed and listed in the table below. Refer to the CSIRO report for the full descriptions of the limitations.

Fibre Type			Style
Wool and wool rich ($\geq 80\%$ wool)	Nylon	Other	
OK for $PT\ 4.1\text{mm} \leq PT \leq 15.2\text{mm}$	OK for $3.8\text{mm} \leq PT \leq 8.0\text{mm}$		Cut Pile
	OK for $3.5\text{mm} \leq PT \leq 6.6\text{mm}$	<i>insufficient data</i>	Loop Pile

The above SRC does not relate to surfaces on ramps steeper than 1:14 of Class 2 to 9 buildings and 1:8 of Class 1 and 10 buildings; or surfaces in wet areas; and may not be used for these applications.

Issued on the 1st day of May 2020.

TERM OF VALIDITY: This report will expire on the 1st day of May 2025.



Alex Webb

Team Leader, Materials Performance

Copyright CSIRO 2020 ©. Copying or alteration of this report without written authorisation from CSIRO is forbidden.

CSIRO INFRASTRUCTURE TECHNOLOGIES

14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555 www.csiro.au

